

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1130:184 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Honeywell Inc., 1500 W. Dundee Road, Arlington Heights, IL 60004
Contact: Bob Hodgson (847) 797-4403

DESIGN: Models XLS757-3A-SS25, XLS757-3A-SS70, XLS757-5A-SS25, XLS757-5A-SS70, XLS757-7A-SS25, XLS757-7A-SS70, XLS757-8A-SS25, XLS757-8A-SS70 speaker/strobes. Unit may be followed by A through Z to indicate product color. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:

Candela:	-5A: 15cd -3A: 30cd -7A: 15/75cd -8A: 110cd
Electrical:	25 and 70 Vrms

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, candela/electrical rating and UL label.

APPROVAL: Listed as speaker/strobes for use with separately listed compatible fire alarm control units. Suitable for the hearing impaired applications. Intended for indoor use only.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

XLF: 7125-1388:204

06-03-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 13, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**